

June 21, 2021

**ADDENDUM NO. 1
TO
CONTRACT DOCUMENTS
FOR
Proposal, Specifications & Bid Documents
2021 Huron County Engineer's Mechanic Shop Roofing Project**

ATTENTION BIDDERS:

These modifications are to be taken into account in preparing proposals. They shall be subject to all terms, limitations and provisions of the original contract documents, and shall be included and made a part of any contracts executed for this project. The Bidders will be responsible for including this addendum in subject contract.

Submitted Question:

"...Would you be able and willing to make it so we would be able to use EPS insulation instead of Poly-Iso?"

Response to Question:

EPS insulation is an acceptable alternative to the poly-iso insulation board as specified in the description of work in the bid documents.

END OF ADDENDUM NO. 1